

Mr D Hudec
A C Plastic Industries Limited
Armstrong Road
Daneshill East
Basingstoke
RG24 8NU

Direct tel: 01923 665101

Our reference BWL4523

Your reference

30 August 2001

Dear Mr Hudec

**APPROVAL OF AUTOMATIC SPRINKLER EQUIPMENT
3.5M SPRINKLER TANK**

I am pleased to confirm that the 3.5m Pump Suction Tank detailed below is LPCB approved and Listed as follows:

**APPROVED FIRE AND SECURITY PRODUCTS AND SERVICES
SUCTION TANKS FOR AUTOMATIC PUMPS**


A C Plastic Industries Limited
Armstrong Road, Daneshill East, Basingstoke RG24 8NU

Tel: +44 (0)1256 329334 Fax: +44 (0)1256 817862

	Maximum Capacity	LPCB Ref. No.
Aquastow rectangular sectional GRP tank Maximum height 3.5m	1300m ³	065a /01A 065a /01B 065a /01C 065a /01D

Note: All tank approvals are strictly subject to tanks being supplied in accordance with LPCB Approval Conditions set out in the 'Introduction'. For galvanised steel tanks, Types A and D the designation 'g' refers to tanks protected by 610g/m² each side and the designation 'e' refers to equivalent corrosion protection as set out in Item 5 of the Introduction.

Yours sincerely



Brian Lywood
Certification Scheme Manager

